

Questions received 2/11/2020

1. What Engineering/Analysis software will the consultant be required to use as part of this RFQ? Is the consultant expected to procure software or will licenses be available?
Franklin Power & Light does not have any Analysis software at this time.
2. Task 2 states “Expected focus areas for the field assessments and interviews with the Utility’s staff”- Will the consultant be expected to provide field support services as part of this RFQ or will Franklin Municipal Power and Light assign their own field personnel when the consultant needs information to be field verified?
FP&L field personnel will be utilized.
3. In what software is the Distribution system currently modeled?
FP&L has primary circuits drawn on AutoCad, does not include secondaries.
4. Will the assessment include planning for DER (e.g. PV, BEES, etc)?
At this time FP&L has no plans for Distributed Energy Resources due to constraints with our wholesale power contract.
5. Does Franklin Municipal Power and Light have specific design guidelines or a design manual that each project must adhere to?
FP&L does not have a design manual. Mainly RUS specifications are utilized.
6. Does Franklin Municipal Power and Light have a reliability planning criteria?
FP&L does not have a reliability plan.